



Test Report issued under the responsibility of



TEST REPORT

IEC 60 898-2:2003

Circuit-Breakers for over current protection for household and similar installation Part 2: Circuit-breakers for a.c. and d.c. operation

Report Reference No.....	00901-CB2014CQC-063787-2	
Tested by (name+signature).....	Cheng Yanmin	
Witnessed by (name+signature).....		
Supervised by (name+signature).....		
Approved by (name+signature)	Wei Qingyuan	
Date of issue.....	2014-12-24	
CB Testing Laboratory.....	Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)	
Address.....	505 Wu Ning Road Shanghai P. R. China	
Testing location/ procedure	CBTL ☒ TMP ☐ WMT ☐ SMT ☐ RMT ☐	
Testing location/ address.....	505 Wu Ning Road Shanghai P. R. China	
Applicant's Name	Zhengjiang Tengen Electrics Co., Ltd.	
Address	Tengen Industry Zone, Liushi, Yueqing, Zhejiang, P.R.China	
Test specification:		
Standard	IEC 60898-2:2000 + Amendment 1:2003	
Test procedure	CB	
Non-standard test method	N/A	
Test Report Form No.....	IEC60898_2A	
Test Report Form(s) Originator	CQC-TILVA	
Master TRF	Dated 2006-06	

Copyright © 2006 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo shall be removed

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description	Miniature Circuit-breaker
Trademark	TENGEN
Manufacturer	Zhengjiang Tengen Electrics Co., Ltd. Tengen Industry Zone, Liushi, Yueqing, Zhejiang, P.R.China
Model/Type reference.....	TGB1Z-63
Ratings.....	TGB1Z-63 Ue: DC125V(1P),DC250V(2P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Instantaneous tripping current: B,C; Icn=Ics=6kA(1A~40A), 4.5kA(50A,63A); 1P,2P