



Test Report issued under the responsibility of



TEST REPORT

IEC 60 898-2:2003

Circuit-Breakers for over current protection for household and similar installation Part 2: Circuit-breakers for a.c. and d.c. operation

Report Reference No.: 03601-A-13CB0094-S-A

Tested by (name+signature).....: Dai Weiqiang

Witnessed by (name+signature).....:

Supervised by (name+signature).....:

Approved by (name+signature): Hu Delin

Date of issue.....: 2013-12-14

CB Testing Laboratory.....: Suzhou Electrical Apparatus Science Research Institute Stock Co., Ltd.(EETI)

Address.....: No.7 Yonghe Street, Binhe Road, New District, Suzhou, China

Testing location/ procedure: CBTL ☒ TMP ☐ WMT ☐ SMT ☐ RMT ☐

Testing location/ address.....: No.7 Yonghe Street, Binhe Road, New District, Suzhou, China

Applicant's Name: Zhejiang Tengen Electrics Co., Ltd.

Address: Tengen Industry Zone, Liushi, Yueqing, Zhejiang, P.R. China

Test specification:

Standard: IEC 60898-2:2000 + Amendment 1:2003

Test procedure: CB

Non-standard test method

Test Report Form No.....: IEC60898_2A

Test Report Form(s) Originator: CQC-TILVA

Master TRF.....: Dated 2006-06

Copyright © 2006 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo shall be removed

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description	Miniature Circuit-Breaker
Trademark	TENGEN
Manufacturer	Zhejiang Tengen Electrics Co., Ltd.
Model/Type reference.....	TGBZ-63
Ratings.....	Ue: AC230V/AC400V/DC125V; In: 1A,2A,3A,4A,5A,6A,10A,16A,20A,25A,32A,40A,50A,63A; Instantaneous tripping type: B,C; Ics=Icn:6kA; Poles: 1P;