



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Certificate No.: CE150303004505

Product

Moulded Case Circuit-Breaker

Applicant

Zhejiang Tengen Electrics Co., Ltd.
TENGEN Industry Zone, Liushi, Yueqing, Zhejiang, P.R. China

Type/model

TGM1-225

Technical data

Ue: AC400V, AC690V; In: 100A, 125A, 160A, 180A, 200A, 225A; Type of over-current release: thermal and magnetic; L
type: AC400V: Ics=22kA, Icu=35kA; AC690V: Ics=4kA, Icu=5kA; M
Type: AC400V: Ics=35kA, Icu=50kA; AC690V: Ics=5kA, Icu=10kA;
Category: A; 3P(L, M), 4P(M type); auxiliary circuits: F-M1 AC-
15: AC380V/0.3A, DC-13: DC220V/0.15A

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2014CQC0303-006918, the submitted sample of the above item complies with:

EN 60947-2:2006(4th edition)

and fulfill testing requirement of the European Directive:

2006/95/EC

President:



Date of issue: Apr. 27, 2015

Date of expiration: Apr. 27, 2018



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>