



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE180303005796

Product

Moulded Case Circuit-Breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGM1-250

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2018CQC0303-009349, the submitted sample(s) of the above item complies with:

EN 60947-2:2006 + A1:2009 + A2:2013

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: May.09,2018

Valid until: May.09,2021

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE180303005796

TGM1-250

Ue: AC415V, AC690V; Uimp:8kV; Ui:800V

In: 100A, 125A, 160A, 180A, 200A, 225A, 250A;

Over-current release: thermo-magnetic;

Type L: AC415V Ics= 22kA Icu= 35kA; AC690V Ics= 4kA Icu= 5kA;

Type M: AC415V Ics= 35kA Icu= 50kA; AC690V Ics= 5kA Icu= 10kA;

Selectivity category: A;

Rated Frequency:50/60Hz;

Suitability for insulation; 2P(AC415V);

3P, 4P(AC415/690V)

Auxiliary contact(1NO+1NC, 2NO+2NC, 4NO+4NC): Ith: 3A,Ui:690V AC-15: AC415/0,3A;

DC-13: DC220V/0,15A

Accessories with electronic circuits: Motor operator: CDM3-225/M, Us: AC240V, AC415V Shunt release: 225FT, Us: AC240V Undervoltage release: 225QT, Us: AC240V, AC415V

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>