



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE140314004398-A1

Product

Miniature circuit breaker

Applicant

Zhejiang Tengen Electric Co., Ltd.

Sulv Industry Zone, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGB2-63

Technical data

Ue: AC230/400V(1P) , AC400V (2P,3P,4P);In:
1A,2A,3A,4A,5A,6A,10A,16A,20A,25A,32A,40A,50A,63A
;Type C ,Type D;Ics=Icn: 6kA; 1P, 2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-17D0052-S, the submitted sample(s) of the above item complies with:

EN 60898-1:2003 + A11:2005

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Aug.21,2017

Valid until: Aug.21,2020

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>