



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE180303006115

Product

Moulded-Case Circuit Breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGB3-125 ,TGB3H-125

Technical data

Ue:
AC230V(1P),AC400V(2P,3P,4P);50/60Hz;In:63A,80A,100
A,125A;Ui: 500V;Uimp:6kV; TGB3-125: Ics: 6kA; Icu:
6kA; TGB3H-125: Ics: 7,5kA; Icu:10kA; Utilization
Category:A; 1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
CE-045-1C180847, the submitted sample(s) of the above item complies with:

EN 60947-2:2006 + A1:2009 + A2:2013

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jan.04,2019

Valid until: Jan.04,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>