

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Moulded Case Circuit-breakers

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Zhejiang Tengen Electric Co.,Ltd.

No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

See the Appendix

**TENGEN** 

TGM3E-630M, TGM3E-630H

IEC 60947-2:2016(5th Edition)

00901-CB2018CQC-083305

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282 website: http://www.cqc.com.cn

Date: Feb.15,2019

Signature: N\$ 45







TGM3E-630M, TGM3E-630H

Ui:1000V; Uimp:8kV;

Ue: AC380/400/415V,AC660/690V; In: 630A(250A~630A adjustable);

Electronic;

AC380/400/415V: lcs=70kA(M type), lcu =70kA(M type), lcw=8kA/1s(M type);

lcs=70kA(H), lcu =100kA(H type), lcw=8kA/1s(H type);

AC660/690V: lcs=20kA(M type), lcu =20kA(M type);

Ics=20kA(H type), Icu =30kA(H type);

Selectivity category:B;

50/60Hz;

Suitable for insulation(except for 3P+N);

IP20;

3P,3P+N,4P(3 protected poles with a switched neutral pole),4P;

Auxiliary contacts(OF-M) and alarm contacts(SD-M):

1NO1NC,2NO2NC,4NO4NC

Ith: 6A;

AC-15: Ue/le: AC380/400/415V/0.3A; DC-13: Ue/le: DC110/220/250V/0.15A;

Electronic Accessories complied with Annex N:

Undervoltage release QT: AC220/230V, AC380/400V;

Motor operator CD2: AC220/230V, AC380/400V;

Shunt release for prepayment meter FT: AC220V;

Shunt release for alarm accessory: AC220V,DC24V.

Page 1 of 1

Additional information (if necessary)

Signature:

专和

Lu Me

Date:

Feb.15,2019