



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190314006493

Product

Miniature circuit breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGBK-63、TGBK-63H、TGB1-63、TGB1-63H、TGBK-63L、
TGBK-63HL;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2017CQC0314-009077-1,00901-CE2017CQC0314-009077-2, the submitted
sample(s) of the above item complies with:

EN 60898-2:2006;EN 60898-1:2003 + A13:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Oct.12,2019

Valid until: Oct.12,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE190314006493

TGBK-63、TGBK-63H、TGB1-63、TGB1-63H、TGBK-63L、TGBK-63HL

Uimp:4kV;

Ui: 690V;

Ue: AC220V/380V、AC230V/400V、AC240V/415V、DC60V/125V(1P);

AC220V/230V/240V(1P+N); AC220V/230V/240V、AC380V/400V/415V、

DC110V/250V (2P); AC380V/400V/415V(3P、3P+N、4P)

In: 1A,2A,3A,4A,5A,6A,10A,16A,20A,25A,32A,40A,50A,63A;

Instantaneous tripping current :B,C,D;

Ics: 7500A[only TGBK-63、TGB1-63、TGBK-63L: AC220V/230V/240V(2P)、DC60V(1P)、

DC110V(2P)、TGBK-63H、TGB1-63H、

TGBK-63HL)];

Ics=Icn: 6000A;

Icn:10000A;

Poles: 1P,1P+N(one protected pole with a switched neutral pole)2P,3P,3P+N(three protected pole with a switched neutral pole),4P;

50/60Hz

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>