

产品认证证书

II型自愿认证

证书编号: CQC2017010307013179

发证日期: 2020年08月24日

有效期至: 2031年05月20日

委托人名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
制造商名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
生产企业名称	浙江天正电气股份有限公司
及生产地址	浙江省乐清市柳市镇柳乐路 332 号
产品名称和系列、 规格、型号	电能表外置断路器 TGB2D-80RH,TGB2D-80RN,TGBG-80RH,TGBG-80RN;Ue: AC230V (1P+N、2P)、400V (3P+N、4P); In: 10A、16A、20A、25A、32A、40A、50A、63A、80A; Ui: 500V; Uimp: 6kV; 瞬时脱扣类型: C 型; TGB2D-80RH、TGBG-80RH: Ics=7.5kA、Icn=10kA; TGB2D-80RN、TGBG-80RN: Ics=Icn: 6kA; 极数: 1P+N (带一个保护极, N 极可开闭)、2P (带两个保护极)、3P+N (带三个保护极, N 极可开闭)、4P (带四个保护极); 控制方式: 远程全自动控制方式; 控制电平电压: AC 220V
产品标准和技术要求	GB/T10963.1-2005
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056219

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010307013179

Valid from: Aug.24,2020

Valid until:May.20,2031

NAME AND REGISTERED
ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co., Ltd.
Solv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER

Zhejiang Tengen Electric Co., Ltd.
Solv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION
OF THE FACTORY

Zhejiang Tengen Electric Co., Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL
AND SPECIFICATION

External Circuit-breakers for Electricity Meters
TGB2D-80RH, TGB2D-80RN, TGBG-80RH, TGBG-80RN; Ue: AC230V (1P+N, 2P), 400V (3P+N, 4P); In: 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A; Ui: 500V; Uimp: 6kV; Type: C; TGB2D-80RH, TGBG-80RH: Ics=7.5kA, Icn=10kA; TGB2D-80RN, TGBG-80RN: Ics=Icn=6kA; Poles: 1P+N (with one protected pole, switched N pole), 2P, 3P+N (with three protected poles, switched N pole), 4P; Remote automatic control mode; Uc: AC220V
GB/T10963.1-2005

THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS

TYPE OF CERTIFICATION
SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056219