

产品认证证书

II型自愿认证

证书编号: CQC2017010307987732

发证日期: 2020年08月24日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正电气股份有限公司
及生产地址 浙江省乐清市柳市镇柳乐路332号

产品名称和系列、规格、型号 塑料外壳式断路器
TGBKZ-63、TGBKZ-63H; 详细参数见附件

产品标准和技术要求 GB/T14048.2-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057263

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010307987732

Valid from: Aug.24,2020

Valid until: May.20,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electrical Co.,Ltd.
Sulv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Zhejiang Tengen Electrical Co.,Ltd.
Sulv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Zhejiang Tengen Electrical Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Moulded Case Circuit-breaker
TGBKZ-63 、 TGBKZ-63H; See the Appendix

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0057263

产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010307987732

第 1 页 共 2 页

纸 号: 57263

TGBKZ-63

Ue: AC220V/230V/240 V /380 V /400 V /415V (1P、2P), AC220 V /230 V/240V(1P+N), AC380 V /400 V /415V(3P、3P+N、4P); DC60V/125V (1P 外形), DC110V/250V(2P 外形), DC375V(3P 外形), DC500V(4P 外形);

Ui: 690V; Uimp: 6kV; In: 1A、2A、3A、4A、5A、6A、10A、16A、20A、25A、32A、40A、50A、63A;

使用类别(Cat): A 类; 过电流脱扣器类型: 热磁式;

分断能力: Icu=Ics: 6kA; 另有 Ue: AC220V/230V/240V(2P)、DC60V(1P 外形)、DC110 V (2P 外形): Icu: 10 kA、Ics: 7.5kA;

极数: AC 1P、2P、3P、4P; DC 1P 外形、2P 外形、3P 外形、4P 外形; (均为保护极, 适用于隔离用、AC1P+N (一个保护极, N 极可开闭, 适用于隔离用)、AC3P+N (三个保护极, N 极可开闭, 适用于隔离用); 适用频率: 50/60Hz;

TGBKZ-63H

Ue: AC220V/230V/240 V /380 V /400 V /415V (1P、2P), AC220 V /230 V/240V(1P+N), AC380 V /400 V /415V(3P、3P+N、4P); DC60V/125V (1P 外形), DC110V/250V(2P 外形), DC375V(3P 外形), DC500V(4P 外形);

Ui: 690V; Uimp: 6kV; In: 1A、2A、3A、4A、5A、6A、10A、16A、20A、25A、32A、40A、50A、63A;

使用类别(Cat): A 类; 过电流脱扣器类型: 热磁式;

分断能力: AC Icu: 10 kA、Ics: 7.5kA; DC Icu=10kA;

极数: AC 1P、2P、3P、4P; DC 1P 外形、2P 外形、3P 外形、4P 外形; (均为保护极, 适用于隔离用); AC1P+N (一个保护极, N 极可开闭, 适用于隔离用)、AC3P+N (三个保护

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录


证书编号: CQC2017010307987732

第 2 页 共 2 页

纸 号: 57263

极, N 极可开闭, 适用于隔离用); 适用频率: 50/60Hz;

直流部份接线示意图:



1. + 电压源正极, - 电压源负极.
2. L+ 负载正极, L- 负载负极.
3. 本产品同时满足上述接线图所示的正反接线方式。

注: 此附录与证书同时使用时有效。



中国质量认证中心

