

产品认证证书

II型自愿认证

证书编号: CQC2019010307252034

发证日期: 2020年11月02日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 赛德电气有限公司
及生产地址 浙江省乐清市七里港工业区

产品名称和系列、规格、型号 塑料外壳式断路器
TGM2-□□, TGM2X-□□; 详细参数及型号解释见附件

产品标准和技术要求 GB/T 14048.2-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057299

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010307252034

Valid from: Nov.02,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Saide Electric Co., Ltd.
Qiligang Town Industrial Zone, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Moulded Case Circuit-Breaker
TGM2-□ □, TGM2X-□ □; Detailed parameters and model are explained in the attachment

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.2-2008

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0057299

产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010307252034

第 1 页 共 3 页

纸 号: 57299

TGM2-□□, TGM2X-□□; 型号解释详见附件; U_e : AC415V/AC500V/AC690V; U_i : 1000V; U_{imp} : 8kV; 热磁式 I_n : 250A (175A、200A、225A、250A 可调)、315A (220A、250A、280A、315A 可调)、350A (245A、280A、315A、350A 可调)、400A (280A、320A、360A、400A 可调)、500A (350A、400A、450A、500A 可调)、600A (420A、480A、540A、600A 可调)、630A (440A、500A、600A、630A 可调); 电子式 I_n : 400A (160A~400A 可调), 630A (252A~630A 可调); 过电流脱扣器类型: 热磁式、电子式; 脱扣级别: 20; AC415V: L 型: $I_{cs}=I_{cu}$: 50kA; M 型: $I_{cs}=I_{cu}$: 85kA; H 型: $I_{cs}=I_{cu}$: 100kA; S 型: $I_{cs}=I_{cu}$: 150kA; AC500V: L 型: $I_{cs}=I_{cu}$: 35kA; M 型: $I_{cs}=I_{cu}$: 50kA; H 型: $I_{cs}=I_{cu}$: 60kA; S 型: $I_{cs}=I_{cu}$: 65kA; AC690V: L 型: $I_{cs}=I_{cu}$: 10kA; M 型: $I_{cs}=I_{cu}$: 10kA; H 型: $I_{cs}=I_{cu}$: 15kA; S 型: $I_{cs}=I_{cu}$: 20kA; I_{cw} : 5kA/1s (400A), 8kA/1s (500A、630A), 适用于电子式液晶型; 使用类别: A 类 (热磁式、电子式拨盘型), B 类 (电子式液晶型); 极数: 3P、4P; 适用于隔离用; 配用的辅助触头: 1NO1NC, I_{th} : 6A; AC-12: U_e/I_e : 220V/240V/6A, 380V/440V/6A; AC-15: U_e/I_e : 220V/240V/6A, 380V/440V/6A

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010307252034

第 2 页 共 3 页

纸 号: 57299

型号解释:

SDM6/SDM6X - ☐ ☐ / ☐ ☐
(1) (2) (3) (4) (5)

- (1) SDM6 表示品牌供电市场; SDM6X 表示战略合作市场
(2) 额定电流 (A): 250、315、350、400、500、600、630
(3) 分断能力代号; L 型: 经济型、M 型: 标准型、H 型: 较高分断型、S 型: 高分断型
(4) 极数: (3: 3P, 4: 4P)
(5) 附件代号见表 3

模块部分:

热磁式: ☐ ☐

(1) (2)

电子式: 液晶型: Micrologic 5.0A

拨盘型: Micrologic 2.3

(1) TM: 配电保护 MA: 电动机保护

(2) 额定电流 (A): 250、315、350、400、500、600、630

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010307252034

第 3 页 共 3 页

纸 号: 57299

表 3

附件组合名称	不带附件	报警触头	分励脱扣器	分励 + 报警	一组辅助触头	辅助 + 报警	欠压脱扣器	欠压 + 报警	分励 + 辅助	分励 + 辅助 + 报警	二组辅助触头	二辅助 + 报警	欠电 + 辅助	辅助 + 欠压 + 报警
代号	无	308	310	318	320	328	330	338	340	348	360	368	370	378

注: 此附录与证书同时使用时有效。



中国质量认证中心

