

产品认证证书

II型自愿认证

证书编号: CQC2018010307074761

发证日期: 2020年09月17日

有效期至: 2031年05月20日

委托人名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
制造商名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
生产企业名称	浙江德菱科技股份有限公司
及生产地址	浙江省乐清中心工业园区经七路 477 号合隆防爆电气有限公司 2#生产楼一楼、四楼、五楼
产品名称和系列、规格、型号	剩余电流保护断路器 TGM2LCX-250/3N,TGM2LCX-250/3N/S;Uimp: 8kV; Ui: 1000V; Ue: AC400V; In: 250A(Ir:100A、125A、140A、160A、180A、200A、225A、250A 可调); 过电流脱扣器类型: 电子式; Ics:35kA; Icu:50kA; Icw:3kA/1s;I△n=50mA/100mA/200mA/300mA/400mA/500mA/600mA/800mA 可调;额定剩余动作类型: AC 型;漏电脱扣器的类型: 电子式; I△m:12.5kA;使用类别: A; 极数: 3P+N(三个保护极, 带不可开断中性线, 不适用于隔离用)
产品标准和技术要求	GB/T 14048.2-2008
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056245

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010307074761

Valid from: Sep.17,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
NAME AND LOCATION OF THE FACTORY	ZHEJIANG DELING TECHNOLOGY CO., LTD. 1/F, 4/F, 5/F, 2nd Producing Building, Helong Anti-explosion Electric Co., Ltd, No.477 Jingqi Road, Yueqing Center Industrial Zone, Yueqing, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Residual current protection circuit breaker TGM2LCX-250/3N, TGM2LCX-250/3N/S; Uimp: 8kV; Ui: 1000V; Ue: AC400V; In: 250A (Ir: 100A, 125A, 140A, 160A, 180A, 200A, 225A, 250A adjustable); Over current release type: Electronic type; Ics: 35kA; Icu: 50kA; Icw: 3kA/1s; I _{Δn} = 50mA/100mA/200mA/300mA/400mA/500mA/600mA/800mA adjustable/AC type; Electronic; I _{Δm} : 12.5kA; Utilization Category: A; Poles: 3P+N (With three protective poles, Uninterrupted N Pole, Not suitable for isolation)
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.2-2008
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE

