

Test Report issued under the responsibility of:



<b>TEST REPORT</b> <b>EN 60947-2</b> <b>Low-voltage switchgear and controlgear - Part 2: Circuit-breakers</b>	
Report Number.....:	(2021)FQIIDQCE-0233
Date of issue.....:	2021-12-10
Total number of pages.....:	489
Name of Testing Laboratory preparing the Report.....:	Fujian Inspection and Research Institute for Product Quality (FQII)
Applicant's name .....	Zhejiang Tengen Smart Electrics Co.,Ltd.
Address.....:	No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
<b>Test specification:</b>	
Standard.....:	EN 60947-2:2017/A1:2020
Test procedure .....	CB-Scheme
Non-standard test method .....	N/A
Test Report Form No. ....:	IEC60947_2J
Test Report Form(s) Originator .....	DEKRA Certification B.V.
Master TRF.....:	Dated 2020-03-31
<b>Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b> This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. <del>If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.</del> <b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
<b>General disclaimer:</b>	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	



<b>Test item description</b> .....	MCCB
<b>Trade Mark(s)</b> .....	
<b>Manufacturer</b> .....	Zhejiang Tengen Smart Electrics Co.,Ltd. / No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
<b>Model/Type reference</b> .....	TGM1NE-250M,TGM1NE-250H,TGMKE-250M,TGMKE-250H, TGMGE-250M,TGMGE-250H,TGMHE-250M,TGMHE-250H; TGM1NE-320M,TGM1NE-320H,TGMKE-320M,TGMKE-320H, TGMGE-320M,TGMGE-320H,TGMHE-320M,TGMHE-320H
<b>Ratings</b> .....	<p>Uimp:8kV; Ui:1000V; Ue:AC380/400/415V, AC500/550V, AC660/690V;50/60Hz;Type of over-current release: Electronic;</p> <p>TGM1NE-250M,TGM1NE-250H,TGMKE-250M,TGMKE-250H, TGMGE-250M,TGMGE-250H,TGMHE-250M,TGMHE-250H:</p> <p>In:200A(Ir:80A-200A adjustable+OFF),250A(Ir:100A-250A adjustable+OFF);</p> <p>Type M:</p> <p>Ics:50kA,Icu:50 kA,Icw:3 kA /1s(AC380/400/415V), Ics:30kA,Icu:30 kA,Icw:3 kA /1s(AC500/550V), Ics:10kA,Icu:10 kA,Icw:3 kA /1s(AC660/690V);</p> <p>Type H:</p> <p>Ics:50kA,Icu:85 kA,Icw:3 kA /1s(AC380/400/415V), Ics:40kA,Icu:40 kA,Icw:3 kA /1s(AC500/550V), Ics:10kA,Icu:20 kA,Icw:3 kA /1s(AC660/690V);</p> <p>TGM1NE-320M,TGM1NE-320H,TGMKE-320M,TGMKE-320H, TGMGE-320M,TGMGE-320H,TGMHE-320M,TGMHE-320H:</p> <p>In:200A(Ir:80A-200A adjustable+OFF),250A(Ir:100A-250A adjustable+OFF),320A(Ir:125A-320A adjustable+OFF)</p> <p>Type M:</p> <p>Ics:50kA,Icu:50 kA,Icw:4 kA /1s(AC380/400/415V), Ics:30kA,Icu:30 kA,Icw:4 kA /1s(AC500/550V), Ics:10kA,Icu:10 kA,Icw:4 kA /1s(AC660/690V);</p> <p>Type H:</p> <p>Ics:50kA,Icu:85 kA,Icw:4 kA /1s(AC380/400/415V), Ics:40kA,Icu:40 kA,Icw:4 kA /1s(AC500/550V), Ics:10kA,Icu:20 kA,Icw:4 kA /1s(AC660/690V);</p> <p>Selectivity category:A;</p> <p>3P, 3P+N(3 protected poles with an uninterrupted neutral pole), 4P(3 protected poles with a switched neutral pole), 4P; 3P 4P: suitable for isolation; 3P+N: not suitable for isolation;</p> <p>Electronic accessory complying with annex N:</p> <p>Motor-operators: Uimp:4kV;Ui:690V; Us:AC220/230/240V,AC380/400/415V,50/60Hz;</p> <p>Shunt release with prepayment:Uimp:4kV;Ui:690V; Us: AC220/230/240V,50/60Hz;</p> <p>Undervoltage release: Uimp:4kV;Ui:800V; Us:AC220/230/240V,AC380/400/415V,50/60Hz;</p> <p>Electronic shunt alarm accessory:Uimp:4kV;Ui:690V</p>


Us:AC220/230/240V,AC380/400/415V,50/60Hz;DC24V

Overload alarm no trip accessory:

Us:AC220/230/240V,AC380/400/415V,50/60Hz;DC24V

Shunt release: Uimp:4kV;Ui:690V;

Us:AC380/400/415V,AC220/230/240V,50/60Hz;DC220V,DC110V,DC24V.

<b>Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):</b>		
<input checked="" type="checkbox"/>	<b>CB Testing Laboratory:</b>	Fujian Inspection and Research Institute for Product Quality(FQII)
<b>Testing location/ address.....:</b>		No. 121, Shan Tou Jiao, West Yang Qiao Road, Fuzhou, Fujian, P.R.China& Chuangxin Road, Kuci District, Mawei Economic Development Zone, Fuzhou, Fujian, P.R.China
<b>Tested by (name, function, signature).....:</b>		Zhang Fan (Engineer) 
<b>Approved by (name, function, signature)....:</b>		Wei Yunming (Chief Engineer) 
		
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 1:</b>	
<b>Testing location/ address.....:</b>		
<b>Tested by (name, function, signature):</b>		
<b>Approved by (name, function, signature)....:</b>		
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 2:</b>	
<b>Testing location/ address.....:</b>		
<b>Tested by (name + signature) .....</b>		
<b>Witnessed by (name, function, signature)..:</b>		
<b>Approved by (name, function, signature)....:</b>		
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 3:</b>	
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 4:</b>	
<b>Testing location/ address.....:</b>		
<b>Tested by (name, function, signature):</b>		
<b>Witnessed by (name, function, signature)..:</b>		
<b>Approved by (name, function, signature)....:</b>		
<b>Supervised by (name, function, signature) :</b>		