


Test Report issued under the responsibility of:



TEST REPORT
EN 60947-2
Low-voltage switchgear and controlgear - Part 2: Circuit-breakers

Report Number. : 03601-A-21D0102-S
Date of issue : 2022-01-10
Total number of pages : 253 pages



Name of Testing Laboratory preparing the Report : Suzhou Electrical Apparatus Science Research Institute Co., Ltd. (EETI)

Applicant's name : Zhejiang Tengen Smart Electrics Co., Ltd.

Address : No.2777 West Zhongshan Road, Xiuzhou District, Jiaying, Zhejiang Province, P.R.China.

Test specification:

Standard : EN 60947-2:2017/A1:2020

Test procedure : CCA Scheme

Non-standard test method : N/A

Test Report Form No. : EN60947_2J

Test Report Form(s) Originator.... : DEKRA Certification B.V.

Master TRF : Dated 2020-03-31



Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	Moulded Case Circuit-Breaker	
Trade Mark(s)	Tengen	
Manufacturer	Zhejiang Tengen Smart Electrics Co., Ltd. No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China.	
Model/Type reference	See page 14	
Ratings	See page 14	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
Testing location/ address		No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
Tested by (name, function, signature)		Dai Weiqiang(Team leader) 
Approved by (name, function, signature) ..		Xu Jianlin(Supervisor) 
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address		
Tested by (name, function, signature):		
Approved by (name, function, signature) ..		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address		
Tested by (name + signature).....		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address		
Tested by (name, function, signature):		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
Supervised by (name, function, signature) :		

List of Attachments (including a total number of pages in each attachment):	
Attachment 1: photos of the product (4 pages- 250 to 253)	
Summary of testing:	
In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:	
<input type="checkbox"/> Programme 1 (three pole fully tested) <input checked="" type="checkbox"/> Programme 2 (four pole fully tested) <input type="checkbox"/> Alternative program not applicable	
<p>Tests performed (name of test and test clause):</p> <p>TEST SEQUENCE I Sample No.:#01#02#03#04 8.3.3 General performance characteristics</p> <p>TEST SEQUENCE II (Ics) Sample No.:#05-#08 #15-#17 #21-#24 #31-#34 #46 8.3.4 Rated service short-circuit breaking capacity</p> <p>TEST SEQUENCE III (Icu) Sample No.:#09-#11 #13#18 #25-#27 #29#35 8.3.5 Rated ultimate short-circuit breaking capacity</p> <p>TEST SEQUENCE III (phase+N test) Sample No.:#19#36</p> <p>TEST SEQUENCE IV (Icw): Sample No.:#12#14#28#30 8.3.6 Rated short-time withstand current</p> <p>TEST SEQUENCE IV (phase+N test): Sample No.:#20#37</p> <p>Annex C- Individual pole short-circuit test sequence Sample No.:#43#44#45</p> <p>Annex F –Additional tests for circuit-breakers with electronic over-current protection Sample No.:#39</p> <p>Annex N- Electromagnetic compatibility (EMC) Sample No.:#41#42</p>	<p>Sample No.:#40 Mechanical properties of terminals 8.2.4 Sample No.:#39 Clearances and creepage distances 7.1.4 Insulating material: Comparative tracking index 7.1.4 Resistance to abnormal heat and fire 8.2.1.1.1</p> <p>Sample specifications: TGM1NE-400M/4320CFE1 400A, 4P: #01 with AC240V auxiliary, shunt release with prepayment and power distribution protection, TGM1NE-400M/3350 400A, 3P:#02 with AC240V under voltage release, AC240V shunt release and power distribution protection TGM1NE-630MP/4300CIIIIE1F 630A 4P: #03 motor operators AC240V, with AC240V overload alarm no trip accessory, motor protection and plug-in TGM1NE-630M/3300 630A 3P:#04 TGMHE-400M/3300 400A 3P:#05#06#07 TGMHE-400M/3300 300A 3P:#08 TGMKE-400M/3300 400A 3P:#09-#12 TGMKE-400M/3300 300A 3P:#13-#14 TGMGE-400M/3300 400A 3P:#15-#17 TGMKE-400M/4300CE1 400A 4P : #18-#20 TGMHE-630M/3300 630A 3P: #21-#23 TGMHE-630M/3300 400A 3P :#24 TGMKE-630M/3300 630A 3P :#25-#28 TGMKE-630M/3300 400A 3P:#29-#30 TGMGE-630H/3300 630A 3P :#31-#33 TGMGE-630H/3300 400A 3P:#34 TGMKE-630M/4300CE1 630A 4P #35-#40 TGM1NE-400 #41-#42 (one sample with AC240V communication module (shunt release + alarm contact) and with AC240V overload alarm no trip accessory): TGMHE-400M/3300 300A 3P:#43 TGMHE-400M/3300 300A 3P:#44 TGMKE-630M/3300 630A 3P:#45 TGMGE-400H/3300 300A 3P:#46</p>

	<p>Remark: This test report is based on test report 03601-A-21B0978-S issued on 2021-09-30, all the test results are copied from the test report (except CTI test).</p>
<p>Testing location: No.7 Yonghe Street, Binhe Road, New District, Suzhou,China</p>	
<p>Summary of compliance with National Differences (List of countries addressed): N/A</p>	
<p>Statement concerning the uncertainty of the measurement systems used for the tests (may be required by the product standard or client)</p> <p><input type="checkbox"/> Internal procedure used for type testing through which traceability of the measuring uncertainty has been established: Procedure number, issue date and title:</p> <p>Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.</p> <p><input checked="" type="checkbox"/> Statement not required by the standard used for type testing</p>	