



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006910-A1

Product	Automatic Transfer Switching Equipment
Applicant	Zhejiang Tengen Electric Co.,Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Type/Model	TGQ1NPL-63,TGQKPL-63;
Technical data	Ui:800V(main circuit);500V(control and auxiliary circuits);Ith: 63A;Uimp:8kV(main circuit);4kV(control and auxiliary circuits);Ue: AC230V(2P),AC400V(3P,4P);Ie: 16A,20A,25A,32A,40A,50A,63A;Utilization Category:AC-33A;Icm: 17kA; Icw: 10kA/30ms;Iq:120kA;Class of equipment: PC;Method of controlling:ATSE;2P, 3P, 4P.

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-23D0064-S-A1, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jul.19,2023

Valid until: Jul.18,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE