



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Certificate No.: CE170306005461-A1

Product

Automatic transfer switching equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

TGLD-250,TGQKP-250;

Technical data

Ue:AC400V;Ui:690V;Uimp:8kV;Ith:250A;Ie:160A,180A,200A,225A,250A;Utilization

category:AC-33iB;Icm:17kA;Icw:10kA/30ms;Iq:50kA;

Class of equipment:PC;Method of controlling:ATSE;Number of poles: 3P,4P;Transfer control devices: Uimp:4kV,Ui:400V

This is to certify that, on the basis of the tests undertaken as per Report No. 02401-2011907025, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Aug.27,2020

Valid until: Jul.14,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>