

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50606509 0001

Berichtsnummer Report No.:

CN232NQF 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Smart Electrics
Co., Ltd
No. 2777 West Zhongshan Road,
Xiuzhou District,
Jiaxing
314000 Zhejiang
P.R. China

Prüfzeichen Test Mark:


Regular Production
Surveillance
Safety
Type Approved

www.tuv.com
ID 1111276617

Geprüft nach Tested according to:

EN 60947-5-1:2017

Geräteidentifikation
Product Identification

Produkt: Auxiliary contacts of a switching device ((Auxiliary Switch))

Product:

Modell: Modelle sind auf nächste(r) Seite(n) gelistet

Type: Type designation(s) are listed on the next page(s)

Technische Daten: Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data: Technical Data is listed on the next page(s)

Gültig ab: 2023-10-29

Valid from:

Zertifizierungsstelle:

Certification body:

Ausstellungsdatum: 2023-10-29

Date of issue:

Wencai Zhang

Wencai Zhang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50606509 0001

Berichtsnummer *Report No.:*

CN232NQF 001

Produkt *Product:* Auxiliary contacts of a switching device
((Auxiliary Switch))

Modell *Type:*
Bezeichnung *Designation:*

Type Designation : OF3, SD3(Tengen(Logo))

Utilization Category : AC-12; DC-12

 Rated Operational Voltage(Ue) : AC240V;50/60Hz;
AC415V;50/60Hz;
DC24/48/130V

 Rated Operational Current(Ie) : AC240V/6A(AC-12);
AC415V/3A(AC-12);
DC24V/6A (DC-12);
DC48V/2A (DC-12);
DC130V/1A(DC-12)

Rated Insulation Voltage(Ui) : AC690V

 Rated Impulse Withstand Voltage
(Uimp) : 2.5kV

 Conventional Free Air Thermal
Current(Ith) : 6A

 Conditional Short-circuit
Current : 1000A

Degree of Protection : IP20

Pollution Degree : 3

ANLAGE (Appendix): 1

