

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2329440-0  
**Report Reference** E530977-20230811  
**Date** 17-Aug-2023

**Issued to:** Zhejiang Tengen Electric Co.,Ltd  
No.332 Liule Road, Liushi Town  
Yueqing, Zhejiang Sheng 325604  
China

**This is to certify that representative samples of** JFHR8 - Special-purpose Fuses Certified for Canada - Component  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:** CSA C22.2 No. 248.1:22, 4th Ed., Issue Date: 2022-10-24,  
CSA C22.2 No. 248.13:22, 3rd Ed., Issue Date: 2022-03-31

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2329440-0  
**Report Reference** E530977-20230811  
**Date** 17-Aug-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
RT18, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose
RT19, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose
TGRT18, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose



*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2334171-0  
**Report Reference** E530977-20230811  
**Date** 17-Aug-2023

**Issued to:** Zhejiang Tengen Electric Co.,Ltd  
No.332 Liule Road, Liushi Town  
Yueqing, Zhejiang Sheng 325604  
China

**This is to certify that representative samples of** JFHR2 - Special-purpose Fuses - Component  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.


**Standard(s) for Safety:** UL 248-1, 4th Ed., Issue Date: 2022-10-24, UL 248-13, Edition 3, Issue Date 2022-03-31

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2334171-0  
**Report Reference** E530977-20230811  
**Date** 17-Aug-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
RT18, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose
RT19, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose
TGRT18, followed by -16 thru -63, Ampere rating 16 - 63A, Voltage rating 690Vac.	Fuses - Special Purpose



*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>