



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240305008935

Product

AC contactor

Applicant

Zhejiang Tengen Smart Electrics Co.,Ltd.

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model

TeC5-22,TeC5-22N,TeC5-25,TeC5-25N,
TeC5-32,TeC5-32N,TeC5-38,TeC5-38N

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-24D0044-S, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jun.07,2024

Valid until: Jun.06,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE240305008935

TeC5-22, TeC5-22N, TeC5-25, TeC5-25N,
TeC5-32, TeC5-32N, TeC5-38, TeC5-38N
Ui: 690V; Uimp: 6kV;
Ith: 32A (TeC5-22, TeC5-22N), 40A (TeC5-25, TeC5-25N),
50A (TeC5-32, TeC5-32N, TeC5-38, TeC5-38N);
TeC5-22: AC-1: Ue: AC220V/230V/380V/400V, Ie: 32A
AC-3: Ue: AC220V/230V/380V/400V, Ie: 22A; Ue: AC660V/690V, Ie: 14A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 8.5A; Ue: AC660V/690V, Ie: 4A
TeC5-22N: AC-1: Ue: AC220V/230V/380V/400V, Ie: 32A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 8.5A; Ue: AC660V/690V, Ie: 4A
TeC5-25: AC-1: Ue: AC220V/230V/380V/400V, Ie: 40A
AC-3: Ue: AC220V/230V/380V/400V, Ie: 25A; Ue: AC660V/690V, Ie: 18A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 8.5A; Ue: AC660V/690V, Ie: 4.4A
TeC5-25N: AC-1: Ue: AC220V/230V/380V/400V, Ie: 40A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 8.5A; Ue: AC660V/690V, Ie: 4.4A
TeC5-32: AC-1: Ue: AC220V/230V/380V/400V, Ie: 50A
AC-3: Ue: AC220V/230V/380V/400V, Ie: 32A; Ue: AC660V/690V, Ie: 22A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 12A; Ue: AC660V/690V, Ie: 7.5A
TeC5-32N: AC-1: Ue: AC220V/230V/380V/400V, Ie: 50A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 12A; Ue: AC660V/690V, Ie: 7.5A
TeC5-38: AC-1: Ue: AC220V/230V/380V/400V, Ie: 50A
AC-3: Ue: AC220V/230V/380V/400V, Ie: 38A; Ue: AC660V/690V, Ie: 22A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 14A; Ue: AC660V/690V, Ie: 8.9A
TeC5-38N: AC-1: Ue: AC220V/230V/380V/400V, Ie: 50A
AC-4: Ue: AC220V/230V/380V/400V, Ie: 14A; Ue: AC660V/690V, Ie: 8.9A
Us: AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50Hz;
AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50/60Hz;



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE240305008935


3P;IP20;

Attached auxiliary contacts: (1NO1NC,2 pairs):

Ith:10A;Ui:690V;Uimp:6kV;

AC-15:Ue/Ie:AC380V/0.95A, AC220V/1.6A

DC-13:Ue/Ie:DC220V/0.15A.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE