

IEC

IECEE



TM

Ref. Certif. No.

CN65944

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Yueqing Economic Development Zone Branch of Zhejiang
Tianzheng Electric Co., LTD
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGW3-1600, TGW3-1600H;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-113757

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.23,2024

Signature:

谢肇煦

Xie ZhaoXu



TGW3-1600, TGW3-1600H
Ui:1000V;Uimp:12kV;
Ue: AC380/400/415V,AC660/690V;
In: 200A,250A,400A,630A,800A,1000A,1250A,1600A;
Over-current release:Electronic type;
TGW3-1600:
AC380V/400V/415V:Ics=Icu:50kA;Icw:42kA/1s;
AC660V/690V:Ics=Icu:36kA;Icw:36kA/1s;
TGW3-1600H:
AC380V/400V/415V:Ics=Icu:65kA;Icw:50kA/1s;
AC660V/690V:Ics=Icu:42kA;Icw:42kA/1s;
Selectivity category:B;50/60Hz;
3P,4P;
Applicable for isolation;
Auxiliary contacts(CB certificate CN63712):
4NO4NC,6NO6NC;
Ui:690V;Uimp:6kV;Ith:16A;
AC-15:Ue/Ie:AC400/415V/5A;
DC-13:Ue/Ie:DC220V/0.5A

Page 1 of 1

Additional information (if necessary)

Date:

May.23,2024

Signature:


Xie ZhaoXu