

CE TEST REPORT

Application No.: CE2024CQC0306-014495

Report Ref. No.: CE-045-1CE240002

Name of product: Automatic Transfer Switching Equipment

Model: TGQ3L -250

Name of Laboratory: Zhejiang Testing & Inspection
Institute for Mechanical and
Electrical Products Quality Co.,Ltd.



CHINA QUALITY CERTIFICATION CENTRE

Test Report issued under the responsibility of:

TEST REPORT EN 60947-6-1 Low-voltage switchgear and controlgear Part 6-1: Multiple function equipment – Transfer switching equipment	
Report Number	CE-045-1CE240002
Date of issue	16,07,2024
Total number of pages	46
Name of Testing Laboratory preparing the Report.....	Zhejiang Testing & Inspection Institute for Mechanical and Electrical Products Quality Co.,Ltd.
Applicant's name	Zhejiang Tengen Electric Co.,Ltd.
Address	Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China.
Test specification:	
Standard.....	EN 60947-6-1:2005+A1:2014
Test procedure	CCA Scheme
Non-standard test method	N/A
Test Report Form No.	IEC60947_6_1C
Test Report Form(s) Originator	SGS Fimko Ltd
Master TRF.....	Dated 2019-07-02
Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	