

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50679099 0001

Berichtsnummer Report No.:

CN25QXW2 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

HD 60269-2:2013+A1+A2

Geräteidentifikation
Product Identification
Produkt:

Fuse Holder

Product:

(Fuse base use for cylindrical contact caps fuse link)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2025-05-28

Valid from:
Zertifizierungsstelle:

Certification body:

Ausstellungsdatum:

2025-05-28

Date of issue:

Yongming Yang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50679099 0001

Berichtsnummer *Report No.:*

CN25QXW2 001

Produkt *Product:*

Fuse Holder

(Fuse base use for cylindrical contact caps fuse link)

Modell *Type:***Bezeichnung** *Designation:*

Type Designation

: RT19-32C

Trademark

: (Tengen(Logo))

Rated Voltage(Un)

:AC400/500/690V

Rated Current(In)

:60A

Rated Frequency

:50/60Hz

Number of Poles

:1P/2P/3P/4P

Rated Short-time Peak Withstand Current

:50kA

Impulse Withstand Voltage (Uimp)

:6kV

Rated Insulation Voltage(Ui)

:1000V

Rated Power Acceptance

:10W

Fuse Base Size

:Size 10x38mm

Pollution Degree

:3

ANLAGE (Appendix): 1

